



East Notice Certification Service Co., Ltd.

317/319 3/F, HuiCheng Building, XiangPu Street, DongPu, TianHe, Guangzhou

Tel:+86-020-2331 4234 Fax:+86-020-8256 8534

E-mail:enc@enc-lab.com Web: www.enc-lab.com

TEST RESULT CERTIFICATE

Registration No. : ENC110509GZ73

Certificate Holder : Detech Real Estate and Trading Joint stock Company
Head Office: P301 Detech Building, 15B Pham Hung, Tu Liem, Hanoi, VN
Branch Office: P706 B2 Block, Ham Nghi, My Dinh 1, Tu Liem, Hanoi, VN

Product Designation : Wooden Acoustic Panel

Model Name : 2440*128*15mm

Brand Name : REMAK

Manufacturer : Remak Co., Ltd
Room A68, Building 04, Area A, Junjing Garden, Shishan Town, Nanhai District, Foshan City, Guangdong Province

Test Requested : EN 13501-1:2007+A1:2010 Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests, Class B

Test Results : **CLASSIFICATION: B; S1; d0**

Issue Date: May 12, 2011


Ray Zhou / General Manager

Statement: The certification relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

Recognized by East Notice Certification Service Co., Ltd. in accordance with the EN 13501-1:2007+A1:2010 standard Class B. The certificate doesn't imply assessment of the production. The certificate is only applicable to the equipments described above. This certificate shall not be re-produced except in full without the written approval of East Notice Certification Service Co., Ltd.

Note: This certificate is part of the full test report(s) and should be used in conjunction with it.